



Northwestern Water and Sewer District
2024 Portage Water Main Replacement
WL-306E

ADDENDUM 3

8/16/24

Planholders of the Northwestern Water and Sewer District, 2024 Portage Water Main Replacement, SS-306E, project are hereby notified of the following amendments to the Contract Documents. This Addendum is hereby made a part of the Contract Documents.

DRAWINGS

Under Sheet SR-0.1, Pavement Trench Repair Typical Section (Residential Pavement) – Close Street, Bullet 4, strike “[See Pavement Planing Typical Section]”.

Under Sheet SR-0.1, Pavement Trench Repair Typical Sections (Heavy Roadway) Findlay Pike, Bullet 5, replace “greater than 3” “ with “greater than 5.5” “.

RECEIPT OF THIS ADDENDUM MUST BE ACKNOWLEDGED ON PAGE C-410 - 1 OF THE BID.