



Northwestern Water and Sewer District
2024 McClure Westside Water Main Replacement
WL-2906

ADDENDUM 3

July 26, 2024

Planholders of the Northwestern Water and Sewer District 2024 McClure Westside Water Main Replacement, WL-2906, project are hereby notified of the following amendments to the Contract Documents. This Addendum is hereby made a part of the Contract Documents.

QUESTIONS

The following questions were submitted to the Engineer. The answers provided below are for the clarification of Bidders questions. Questions have been paraphrased for brevity.

Question #1 – Is the Owner providing the adapters for the front and back of the meter pits?

The meter pits will be provided with Ford C14-34-G adapters.

Question #2 – Who will provide inspection for the job?

The District will provide inspection services for the job.

RECEIPT OF THIS ADDENDUM MUST BE ACKNOWLEDGED ON PAGE C-410 - 1 OF THE BID.